

UL Online Certifications Directory

BLIS.R13655 Caulkings and Sealants

[Page Bottom](#)

Caulkings and Sealants

[See General Information for Caulkings and Sealants](#)

THE DOW CHEMICAL CO
901 E KANKAKEE RIVER DR
WILMINGTON, IL 60481 USA

R13655

Foamed plastic caulking and sealants.

	Applied to Inorganic Reinforced Cement Board+
Flame spread	20
Smoke developed	15

+Tested as applied in three 3/4 in. diameter beads 5 in. on center covering 12.5 percent of the exposed test sample area. The material is packaged under pressure.

Foamed plastic caulking and sealants.

	Applied to Inorganic Reinforced Cement Board+
Flame spread	20
Smoke developed	20

+Tested as applied in three 3/4 in. diameter beads 5 in. on center covering 12.5 percent of the exposed test sample area.

	1.75 FROTH 17, 60, 120, 350 Gallon Refill, FP180 or FP600 Applied to Inorganic Reinforced Cement Board+
Flame spread	20
Smoke developed	35-65

+Tested as applied in three 1-1/2 in. diameter beads 5 in. on center covering 25.0 percent of the exposed test sample area.

	1.75 FROTH 17, 60, 120, 350 Gallon Refill, FP180 or FP600 Applied to Inorganic Reinforced Cement Board+
Flame spread	25
Smoke developed	45-85

+Tested as applied in one 6 in. wide strip covering 33.3 percent of the exposed test sample area.

Great Stuff® Acrylic Latex Foam Sealant Applied To Inorganic Reinforced Cement Board+	
Flame spread	0
Smoke developed	0

+Tested as applied in three 3/4 in. diameter beads 5 in. OC covering 12.5 percent of the exposed test sample area.

Great Stuff® Window and Doors Applied to Inorganic Reinforced Cement Board+	
Flame spread	10
Smoke developed	20

+Tested as applied in three 3/4 in. diameter beads 5 in. OC covering 12.5 percent of the exposed test sample area.

Last Updated on 2004-12-07

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2006 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2006 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

