

Cold Air Belly Return System Conversion

- Permanently seal all return grilles
- Seal return air floor opening in the furnace closet
- Create hallway return system by
 - Adding a grille to the Furnace closet with at least 200 Sq. In. of net free area. (If a door is present)
 - Undercut doors to adjacent rooms or install grilles if rooms have a pressure difference greater than 3 Pa.
- Measure the air flow to assure that the airflow is within the manufacturers specifications.

